

# TEST CERTIFICATE

15632 1005 03A

Test according to EN 15632:2009

for

Pre-insulated Bonded Flexible Pipe System

„**CASAFLEX**®“

By order of

**BRUGG Rohrsysteme GmbH**

Germany

Order no. 4876, Report 926, Specimen no. 2635, 2636, 2637:

3 x pipe CASAFLEX® dimension 60/126 from current production at  
BRUGG Rohrsysteme GmbH in Germany

Construction: Stainless steel corrugated carrier pipe ⇒ PIR-insulation with  
monitoring wires ⇒ multi-layer barrier foil ⇒ PE-LD casing pipe

The tube assembly and the components meet all the requirements checked  
according to the European Standard EN 15632-1:2009 and  
EN 15632-4:2009.

Hemmingen, 2010-03-03

FERNWÄRME-FORSCHUNGSINSTITUT  
IN HANNOVER E.V.  
Tel. 05 11/9 43 70-0 · Fax -70  
30966 Hemmingen · Max-von-Laue-Str. 23

  
Thomas Grage  
Managing Director

  
Jens Tödter  
Project Manager