

Test Certificate

No. 489 0701 56Aa

Soil Stress Test According to EN 489:2003

for

Joint System

Electric welded Joint

“ German Pipe[®] Type GP SSM ”

by order of

German Pipe[®] Industrie- und Fernwärmetechnik GmbH

FFI-Report 787A4727

Test Specimens:

Joint for preinsulated tube 2x DN 80/160 mm, 1x DN 150/250 mm

The soil stress test was carried out according to the European Standard EN 489:2003 at the FFI in Jan. 2007: Sandbox test according to EN 489:2003 with 100 cycles for DN 80/160 and 300 cycles for DN 150/250 and water impermeability test according to EN 489:2003.

There was no water ingress.


The soil stress test for the above joint system was successful.

Managing Director:
Dipl.-Ing. Thomas Grage



FERNWÄRME-FORSCHUNGSINSTITUT
IN HANNOVER E.V.
Tel. 05 11/943 70-0 - Fax - 70
30966 Hemmingen - Max-von-Laue-Str. 23

Project Manager:
Dipl.-Ing. (FH) Volker Herbst



Hemmingen, 18-01-2007